



Power Quality Audit

PowerLines Sample Site

Anytown, USA

Facility:	PowerLines Sample Site	Equipment:	Generic CT Scanner Serial Number 12345
	45 Springfield Blvd.	Location #:	
	Anytown, USA	District:	
Installation ISE:	Steve Stephenson	Survey Type:	<input type="checkbox"/> Installation Survey
Primary FSE:	Beth Johnson		<input checked="" type="checkbox"/> Equipment Installed and Operating
Project Manager:	Carl Hibbert		<input type="checkbox"/> Other -
Area Service Manager:	Jacqui Arnold	Power Protection:	PCDU (Line Side Monitoring)

Problem Description

Frequent system resets and lockups

Start Monitoring:	06/20/2002 6:13 PM	Stop Monitoring:	07/18/2002 6:13 PM
Current Monitored:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Equipment in Use:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown
RPM Programmed:	Three Phase Wye	RPM Monitor Period:	4 Weeks
RPM Meter S/N:		RPM Meter Set-up:	Properly Connected and Programmed
Received Data:	31-Aug-02	Report Generated:	2-Sep-02

Summary Power Quality Analysis

Low frequency power factor capacitor impulses are occurring, which cause large (~200 Amp) current to be drawn by the system. These currents may be drawn by the PCDU filters, the CT Scanner rectifier, or other loads within the CT Scanner. This type of event is a known cause of problems for some CT systems.

The PCDU is not designed to attenuate these events due to the extremely low frequency and low amplitude of the ringing impulses.

Check the time and date of these events and compare these to the system event logs or error logs. If there is a correlation, a UPS system or other type of double conversion power conditioning device would be the most appropriate solution.




Category	Summary Analysis	Acceptable	Needs Follow-up	Problem	Not Applicable
Voltage Continuity	No Voltage Outages Recorded	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
RMS Voltage Level	RMS Voltage Level Acceptable	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Voltage Waveforms	Voltage is Sinusoidal and Low THD	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sags and Swells	Minor Voltage Sags - Utility Sourced	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Transient Voltages	PF Correction Capacitor Switching Transients	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mains Impedance	Mains Impedance Acceptable (RPM Calculation)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Voltage Balance	Voltages Balanced	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Neutral-Ground Bonding	Neutral-Ground Appear to be Properly Bonded	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ground Current	Insufficient Data	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Load Current	Moderate Equipment Use During Survey	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Load Generated Disturbances (LGD)	No Load Generated Disturbances	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Recommended Actions


1. Compare the impulse log found on page 14 of this report to any recorded errors or events during the monitored period.
2. If there is a correlation, consult with the AC utility to determine if the capacitor switching transients can be reduced or eliminated. This would involve removing the capacitors, reprogramming the capacitor switching times, or purchasing special zero crossing switches that are designed to reduce switching transients.
3. If utility correction is not possible, a UPS or other type of Double Conversion power protection would be required.
4. See the attached applications note on Power Factor Capacitor switching transients for additional information about this type of event.
5. Consider retapping the PCDU for a slightly lower output voltage (if such a tap is available) since RMS voltage comes close to 8% above nominal.

RMS Voltage and Current Snapshots



Voltage Snapshot

Voltage waveforms were sinusoidal with no significant harmonics or voltage distortion.




Current Snapshot

Current waveforms were typical for a medical imaging system in stand-by condition. The Neutral and Ground current probes did not appear to be connected, or the current level was too low to be recorded.


The RPM Power Analyzer is programmed to take a single "snapshot" of voltage and current waveforms at the start of the monitored period. To acquire the most useful data, the monitoring should be started with all current probes / test leads connected, with AC voltage applied, and with the equipment switched on in stand-by or normal operating modes.

Voltage and Current Harmonics Summary


Average Voltage Harmonics



Average Current Harmonics



The RPM Power Analyzer collects harmonics data continuously during power analysis. The graphs above are a summary or average of harmonics seen during this power survey. These do not necessarily represent the voltage and current harmonics at any specific time, nor the worst case harmonics seen. High voltage harmonics may indicate an excessively distorted voltage waveform.



Phase rotation was correct, and phase balance and levels appeared to be normal. Current and Impedance phasors were normal for a medical imaging system in stand-by mode. The capacitive load is typical for the PCDU primary; the PCDU filter circuits dominate the load under stand-by conditions.

RMS Voltage, Current, and Frequency Levels




Start Date: 06/20/2002 6:13 PM

End Date: 07/18/2002 6:13 PM

Nominal Voltage	277	Phase A - Neutral	Phase B - Neutral	Phase C - Neutral
Voltage				
Minimum		268.4 V rms	276.2 V rms	263.6 V rms
Percent of Nominal		-3.10 %	-0.29 %	-4.84 %
Average		286.5 V rms	288.0 V rms	285.9 V rms
Percent of Nominal		3.43 %	3.97 %	3.21 %
Maximum		299.4 V rms	297.3 V rms	299.4 V rms
Percent of Nominal		8.09 %	7.33 %	8.09 %
Frequency				
Minimum		59.92 Hz	59.92 Hz	59.92 Hz
Average		59.99 Hz	59.99 Hz	59.99 Hz
Maximum		60.07 Hz	60.07 Hz	60.07 Hz
Current		Phase A	Phase B	Phase C
Minimum		4.2 A rms	4.6 A rms	4.9 A rms
Average		5.4 A rms	6.3 A rms	6.8 A rms
Maximum		80.0 A rms	84.8 A rms	78.7 A rms


RMS Voltages were within System Requirements of +/-10% throughout the monitored period. RMS voltages were slightly high - if the system has a small adjustment tap (2.5%) then a lower tapped voltage would be recommended to better align the facility voltage with the system requirements. Frequency was stable, and current was normal for a lightly used medical imaging system.

RMS Voltage Log Graphs


	<p>Phase: Phase A - Neutral</p> <p>Start Date: 06/20/2002 6:13 PM</p> <p>End Date: 07/18/2002 6:13 PM</p> <p>Analysis</p> <p>RMS voltages were stable, with a small daily fluctuation, and occasional minor sags and swells, not outside of system requirements.</p>
	<p>Phase: Phase B - Neutral</p> <p>Start Date: 06/20/2002 6:13 PM</p> <p>End Date: 07/18/2002 6:13 PM</p> <p>Analysis</p> <p>RMS voltages were stable, with a small daily fluctuation, and occasional minor sags and swells, not outside of system requirements.</p>
	<p>Phase: Phase C - Neutral</p> <p>Start Date: 06/20/2002 6:13 PM</p> <p>End Date: 07/18/2002 6:13 PM</p> <p>Analysis</p> <p>RMS voltages were stable, with a small daily fluctuation, and occasional minor sags and swells, not outside of system requirements.</p>

The RPM Power Analyzer records Minimum and Maximum RMS voltage deviations with a one cycle resolution. High and Low voltage deviations as reported above may be as short as one cycle. Significant deviations in RMS voltage will also be reported as voltage sags and swells.


RMS Current Log Graphs



Phase: Phase A
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM
Analysis
RMS Current graphs show three specific operating conditions: system off (night), system ready to image (daytime, slightly higher) and system imaging (current surges or spikes).






Phase: Phase B
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM
Analysis
RMS Current graphs show three specific operating conditions: system off (night), system ready to image (daytime, slightly higher) and system imaging (current surges or spikes).



Phase: Phase C
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM
Analysis
Phase C current was not measured - the Phase C current channel was used to monitor the system ground current.


The RPM Power Analyzer records Minimum and Maximum RMS current deviations with a one cycle resolution. High current deviations as reported above may be a short as one cycle, possibly due to equipment switch-on inrush. Significant changes in current which affect the voltage level or waveshape will also be reported as Load Generated Disturbances.

Frequency Log Graphs

 <p>MRI-CT Diagnostics (PCDU Input#2) Phase A Frequency. Jul 18 2002 18:13:18</p> <p>60.5Hz 60.0Hz 59.5Hz</p> <p>18:13 Jun 20, 2002 5.6 days/div. 18:13 Jul 18, 2002</p> <p>The graph shows a green waveform fluctuating around a 60.0 Hz baseline. The y-axis ranges from 59.5 Hz to 60.5 Hz. The x-axis shows a 5.6-day interval from June 20, 2002 to July 18, 2002.</p>	<p>Phase: Phase A - Neutral</p> <p>Start Date: 06/20/2002 6:13 PM</p> <p>End Date: 07/18/2002 6:13 PM</p> <p>Analysis</p> <p>Frequency was stable throughout the monitored period. (Typical for North American facilities and electrical systems)</p>
 <p>MRI-CT Diagnostics (PCDU Input#2) Phase B Frequency. Jul 18 2002 18:13:18</p> <p>60.5Hz 60.0Hz 59.5Hz</p> <p>18:13 Jun 20, 2002 5.6 days/div. 18:13 Jul 18, 2002</p> <p>The graph shows a green waveform fluctuating around a 60.0 Hz baseline. The y-axis ranges from 59.5 Hz to 60.5 Hz. The x-axis shows a 5.6-day interval from June 20, 2002 to July 18, 2002.</p>	<p>Phase: Phase B - Neutral</p> <p>Start Date: 06/20/2002 6:13 PM</p> <p>End Date: 07/18/2002 6:13 PM</p> <p>Analysis</p> <p>Frequency was stable throughout the monitored period. (Typical for North American facilities and electrical systems)</p>
 <p>MRI-CT Diagnostics (PCDU Input#2) Phase C Frequency. Jul 18 2002 18:13:18</p> <p>60.5Hz 60.0Hz 59.5Hz</p> <p>18:13 Jun 20, 2002 5.6 days/div. 18:13 Jul 18, 2002</p> <p>The graph shows a green waveform fluctuating around a 60.0 Hz baseline. The y-axis ranges from 59.5 Hz to 60.5 Hz. The x-axis shows a 5.6-day interval from June 20, 2002 to July 18, 2002.</p>	<p>Phase: Phase C - Neutral</p> <p>Start Date: 06/20/2002 6:13 PM</p> <p>End Date: 07/18/2002 6:13 PM</p> <p>Analysis</p> <p>Frequency was stable throughout the monitored period. (Typical for North American facilities and electrical systems)</p>


The RPM Power Analyzer records frequency continuously. In the United States, frequency deviations from 60.0 Hz are very rare. In the hospital environment, small frequency changes are often seen on the output of free-running emergency generators or UPS systems, not synchronized to the Utility. Larger frequency deviations are often the result of voltage outages or transients.

Voltage and Current Balance Log Graphs




Voltage Balance is the percentage difference between the RMS voltage of the highest phase and the lowest phase, divided by the average of all phases. Voltage Balance problems can be caused at the Utility level, or within the facility due to unbalanced loading. Current Balance often fluctuates widely, especially in intermittent loads such as medical imaging systems.

Voltage Disturbances: Magnitude vs. Duration Curve




Phase: Phase A - Neutral
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM

Analysis
Voltage Disturbances plotted against typical system requirements (ITIC Curve). All disturbances were within this envelope. However, the RPM Power Analyzer does not always plot some disturbances properly; these may still exceed system requirements.



Phase: Phase B - Neutral
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM

Analysis
Voltage Disturbances plotted against typical system requirements (ITIC Curve). All disturbances were within this envelope. However, the RPM Power Analyzer does not always plot some disturbances properly; these may still exceed system requirements.




Phase: Phase C - Neutral
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM

Analysis
Voltage Disturbances plotted against typical system requirements (ITIC Curve). All disturbances were within this envelope. However, the RPM Power Analyzer does not always plot some disturbances properly; these may still exceed system requirements.


Voltage disturbances are plotted by Magnitude (Vertical) and Duration (Horizontal). Disturbances within the Red Lines above are generally less serious; those outside of the red lines are more likely to cause system problems. Disturbances to the left are higher frequency / shorter (transients, short sags) and those to the right are longer.

Voltage Disturbances: Magnitude vs. Time




Phase: Phase A - Neutral
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM

Analysis
 Voltage Disturbances plotted versus the Time of Occurrence. Disturbances were evenly distributed over the course of the monitored period.



Phase: Phase B - Neutral
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM

Analysis
 Voltage Disturbances plotted versus the Time of Occurrence. Disturbances were evenly distributed over the course of the monitored period.



Phase: Phase C - Neutral
Start Date: 06/20/2002 6:13 PM
End Date: 07/18/2002 6:13 PM

Analysis
 Voltage Disturbances plotted versus the Time of Occurrence. Disturbances were evenly distributed over the course of the monitored period.

Voltage disturbances are plotted by Magnitude (Vertical) and Time of Occurrence (Horizontal). Look for disturbance trends such as time of day, during working hours, or during times when the equipment being monitored is use.

Voltage Outage Events

0 Voltage Outages were recorded during the surveyed period.

Although no voltage outages were recorded, such findings over a relatively short power audit are not conclusive indications of long term facility or utility continuity of service. Protection for computers, consoles, and control systems such as an Uninterruptible Power System (UPS) may be warranted to ensure continuity of service and minimum loss of use during actual Utility outages.

Voltage Sags and Swells



3 Voltage Sags / Swells were recorded during the surveyed period.

All of these voltage sags were less than 5% below nominal - well within the system requirements. They are listed here and detailed for information and interest.

Load generated voltage sags and swells (if any) are included in a separate section of this report.

Number	Type	Amplitude	Duration	Date and Time
822	26	264.176	0.05	Jul 12 2002 03:35:21.492
790	30	268.449	0.017	Jul 03 2002 17:40:18.548
780	26	269.67	0.033	Jul 03 2002 17:40:18.547

Individual Voltage Sags and Swells

<p>MRI-CT Diagnostics (PCDU Input#2) Phase C Voltage. (Event 822). Jul 12 2002 03:35:21.492</p>  <p>26.667 milliseconds/div. 264.17V 50 milliseconds duration.</p>	<p>Event Number: 822 Date: 12-Jul-02 Time: 3:35:00 AM Duration: 4 cycles Analysis A very minor voltage sag, not outside of equipment specifications, and not causing any change in system load current.</p>
<p>MRI-CT Diagnostics (PCDU Input#2) Phase A Transition Voltage. (Event 770). Jul 03 2002 17:40:18.488</p>  <p>26.667 milliseconds/div.</p>	<p>Event Number: 770 Date: 3-Jul-02 Time: 5:40:18 PM Duration: 3 cycles Analysis A very minor voltage sag, not outside of equipment specifications, and not causing any change in system load current.</p>

Voltage Transients and Impulses

32 Voltage Transients and Impulses were recorded during the surveyed period.

The RPM power analyzer captured 32 low frequency transient events, listed here. Unfortunately, the RPM summary software is not able to identify, classify, or highlight these events as voltage transients. Identification of these involves manually reviewing all event data and visually scanning all waveforms.




Each of these events is a low frequency impulse, probably related to utility switching of capacitor banks, used to correct low power factor. For a better understanding of these events, review the technical note appended to this report.

Compare this table (dates and times) to the equipment error or event logs - if there is correlation, these impulses are probably causing system problems. This type of event has been known to affect CT systems at other sites, if the transients are severe enough.

Load generated voltage transients and impulses (if any) are included in a separate section of this report.

Number	Type	Amplitude	Duration	Date and Time
10	30	287.127	0.017	Jun 21 2002 08:13:34.613
31	30	286.028	0.017	Jun 21 2002 08:13:34.615
32	30	284.685	0.017	Jun 21 2002 08:13:34.616
71	30	288.226	0.017	Jun 22 2002 10:03:20.232
30	30	286.272	0.017	Jun 22 2002 10:03:20.233
112	30	285.784	0.017	Jun 22 2002 10:03:20.238
70	30	283.953	0.017	Jun 24 2002 07:08:28.32
590	30	285.906	0.017	Jun 29 2002 10:08:14.579
371	30	287.615	0.017	Jun 29 2002 10:08:14.583
472	30	285.54	0.017	Jun 29 2002 10:08:14.583
610	26	299.457	0.033	Jun 30 2002 10:44:05.460
411	30	287.249	0.017	Jun 30 2002 10:44:05.519
512	26	299.457	0.017	Jun 30 2002 10:44:05.521
630	30	284.93	0.017	Jun 30 2002 14:22:49.307
650	30	286.639	0.017	Jul 01 2002 08:29:15.592
451	30	288.348	0.017	Jul 01 2002 08:29:15.594
572	30	285.784	0.017	Jul 01 2002 08:29:15.596
670	26	298.846	0.033	Jul 01 2002 14:19:57.827
491	30	287.249	0.017	Jul 01 2002 14:19:57.878
612	26	298.968	0.017	Jul 01 2002 14:19:57.884
632	30	284.441	0.017	Jul 02 2002 10:14:35.162
810	30	283.342	0.017	Jul 04 2002 10:35:27.128
732	30	285.662	0.017	Jul 07 2002 10:45:47.181
850	30	286.394	0.017	Jul 07 2002 10:45:47.185
531	30	287.859	0.017	Jul 07 2002 10:45:47.186
752	30	284.563	0.017	Jul 08 2002 14:48:11.398
571	30	288.226	0.017	Jul 12 2002 11:16:05.600
852	30	285.906	0.017	Jul 12 2002 11:16:05.601
691	30	287.981	0.017	Jul 13 2002 10:01:35.872
1010	30	287.127	0.017	Jul 13 2002 10:01:35.873
992	30	286.15	0.017	Jul 13 2002 10:01:35.878
1070	30	283.342	0.017	Jul 16 2002 07:07:18.888




Individual Voltage Transients

<p>MRI-CT Diagnostics (PCDU Input#2) Phase A Transition Voltage. (Event 10). Jun 21 2002 08:13:34.613</p>  <p>500V 0V -500V 10.008 milliseconds/div.</p>	<p>Event Number: 10 Date: 21-Jun-02 Time: 8:13:34 AM Duration: 1/4 cycle Analysis A low frequency impulse, at the voltage peak, causes a significant overvoltage condition. The medical imaging load draws a large current surge as a result (scale = +/-200 Amps).</p>
<p>MRI-CT Diagnostics (PCDU Input#2) Phase B Transition Voltage. (Event 31). Jun 21 2002 08:13:34.615</p>  <p>500V 0V -500V 6.716 milliseconds/div.</p>	<p>Event Number: 31 Date: 21-Jun-02 Time: 8:13:34 AM Duration: 1/4 cycle Analysis A low frequency impulse, near the zero-crossing of voltage, may disrupt control systems and power conversion circuits that are triggered off the AC frequency or voltage zero-crossing.</p>
<p>MRI-CT Diagnostics (PCDU Input#2) Phase C Transition Voltage. (Event 32). Jun 21 2002 08:13:34.616</p>  <p>500V 0V -500V 6.782 milliseconds/div.</p>	<p>Event Number: 32 Date: 21-Jun-02 Time: 8:13:34 AM Duration: 1/4 cycle Analysis A low frequency impulse, at the voltage peak, causes a significant overvoltage condition. The medical imaging load draws a large current surge as a result (scale = +/-200 Amps).</p>

Individual Voltage Transients (continued)

<p>MRI-CT Diagnostics (PCDU Input#2) Phase A Transition Voltage. (Event 30). Jun 22 2002 10:03:20.233</p> <p>500V 0V -500V 10.008 milliseconds/div</p>	<p>Event Number: 30 Date: 22-Jun-02 Time: 10:03:20 AM Duration: 1/4 cycle Analysis A low frequency impulse, at the voltage peak, causes a significant overvoltage condition. The medical imaging load draws a large current surge as a result (scale = +/-200 Amps).</p>
<p>MRI-CT Diagnostics (PCDU Input#2) Phase B Transition Voltage. (Event 71). Jun 22 2002 10:03:20.232</p> <p>500V 0V -500V 6.716 milliseconds/div</p>	<p>Event Number: 71 Date: 22-Jun-02 Time: 10:03:20 AM Duration: 1/4 cycle Analysis A low frequency impulse, near the zero-crossing of voltage, may disrupt control systems and power conversion circuits that are triggered off the AC frequency or voltage zero-crossing.</p>
<p>MRI-CT Diagnostics (PCDU Input#2) Phase C Transition Voltage. (Event 112). Jun 22 2002 10:03:20.238</p> <p>500V 0V -500V 10.272 milliseconds/div</p>	<p>Event Number: 112 Date: 22-Jun-02 Time: 10:03:20 AM Duration: 1/4 cycle Analysis A low frequency impulse, at the voltage peak, causes a significant overvoltage condition. The medical imaging load draws a large current surge as a result (scale = +/-200 Amps).</p>

Individual Voltage Transients (continued)

<p>MRI-CT Diagnostics (PCDU Input#2) Phase A Transition Voltage. (Event 70). Jun 24 2002 07:08:28.32</p>  <p>500V 0V -500V 10.206 milliseconds/div</p>	<p>Event Number: 70 Date: 24-Jun-02 Time: 7:08:28 AM Duration: 1/4 cycle Analysis A low frequency impulse, which does not appear to cause equipment disruption or a significant flow of current.</p>
<p>MRI-CT Diagnostics (PCDU Input#2) Phase A Transition Voltage. (Event 590). Jun 29 2002 10:08:14.579</p>  <p>200A 0A -200A 10.206 milliseconds/div</p>	<p>Event Number: 590 Date: 29-Jun-02 Time: 10:08:14 AM Duration: 1/4 cycle Analysis A low frequency impulse, at the voltage peak, causes a significant overvoltage condition. The medical imaging load draws a large current surge as a result (scale = +/-200 Amps).</p>
<p>MRI-CT Diagnostics (PCDU Input#2) Phase B Transition Voltage. (Event 371). Jun 29 2002 10:08:14.583</p>  <p>500V 0V -500V 6.782 milliseconds/div</p>	<p>Event Number: 371 Date: 29-Jun-02 Time: 10:08:14 AM Duration: 1/4 cycle Analysis A low frequency impulse, at the voltage peak, causes a significant overvoltage condition. The medical imaging load draws a large current surge as a result (scale = +/-200 Amps).</p>

Individual Voltage Transients (continued)

	<p>Event Number: 472 Date: 29-Jun-02 Time: 10:08:14 AM Duration: 1/4 cycle Analysis A low frequency impulse, at the voltage peak, causes a significant overvoltage condition. The medical imaging load draws a large current surge as a result (scale = +/-400 Amps).</p>
	<p>Event Number: 610 Date: 30-Jun-02 Time: 10:44:05 AM Duration: 1/4 cycle Analysis A low frequency impulse, at the voltage peak, causes a significant overvoltage condition. The medical imaging load draws a large current surge as a result.</p>
	<p>Event Number: 630 Date: 30-Jun-02 Time: 2:22:49 PM Duration: 1/4 cycle Analysis A low frequency impulse, which does not appear to cause equipment disruption or a significant flow of current.</p>

Load Generated Events


In many cases, the source impedance of the facility electrical system, or the output impedance of a transformer, power conditioner, or UPS system will contribute to voltage disturbances when the medical imaging load draws current. The voltage events can be sags, swells, or transients (impulses). The current changes that cause these may be normal equipment operating currents, switch-on inrush currents, or unexpected fault currents. This type of disturbance is referred to as a **Load Generated Disturbance**.

Load Generated Disturbances are not caused by the Electrical Utility, or by other loads in the facility. Instead, they are a product of the load current, acting upon the source impedance (resistance or inductance).

An excessive magnitude or number of Load Generated Disturbances can indicate that the electrical system or power source feeding this equipment is undersized, requires maintenance, or is misapplied to the medical imaging system.

No significant load generated disturbances were recorded. It appears that the source is fairly stiff, with low impedance, and is able to supply the instantaneous demand of the medical imaging load.

Individual Load Generated Disturbances



Neutral / Ground Voltage and Current Graphs

